

















ID NO: 010		COSHH ASSESSMENT RECORD		DOWSE	
SUBSTANCE		HYDRATED LIME			
IDENTIFICATION		Free flowing, very fine white powder.			
PROCESS/OR USE		Use as a constituent of mortar.			
RISKS TO HEALTH		Irritating to eyes and skin. Risk of serious damage to eyes. May cause burns in the presence of moisture.			
CAN THE EXPOSURE BE ELIMINATED				NO	Details specified below
		FIRST AID MEASURES EYES: Wash immediately with copious amounts of water. SKIN: Wash thoroughly with soapy water. INHALATION: Remove to fresh air. INGESTION: Wash mouth out with water and give milk to drink.			
COPY MUST BE SENT WITH INJURED PARTY TO HOSPITAL					
		FIRE FIGHTING MEASURES (Tick Box)  <input type="checkbox"/>  <input type="checkbox"/>  <input type="checkbox"/>  <input type="checkbox"/>			
		SPILLAGE & ENVIRONMENTAL DETAILS Wear correct PPE avoid skin and eye contact and avoid breathing in dust. Contained spilled product with sand or earth or other absorbent material. Prevent spills entering waterways and drains. Notify Environment Agency or other bodies if spills enter waterways or drains.			
		EXPOSURE LIMITS (EH 40) Time Exposed: _____ Number of People Exposed: _____ Workplace Exposure Limit (WEL) Long Term Exposure Limit - 8 Hour TWA NA ppm Inhalable 10 mg.m ⁻³ Respirable 4 mg.m ⁻³ Short Term Exposure Limit - 15 Minute NA ppm NA mg.m ⁻³			
PPE (Tick Box)		 <input checked="" type="checkbox"/>  <input checked="" type="checkbox"/>  <input type="checkbox"/>  <input type="checkbox"/>  <input checked="" type="checkbox"/>  <input checked="" type="checkbox"/>  <input checked="" type="checkbox"/>			
CONTROL MEASURES		Advise all persons involved in the use of hydrated lime on the inherent dangers of cement in the form of site start up briefing. Thorough site supervision to be maintained to ensure that PPE is worn without exemption.			Site Agent
Assessment By: Risk Advisor		Date: Apr 2005		Review Date: Apr 2010 (maximum 5 years)	

